



Jim Doyle, Governor
Jack L. Fischer, A.I.A., Secretary

September 18, 2008

DTR CONCRETE PRODUCTS, LLC
DUANE ROFFERS
W 361 COUNTY RD EE
DE PERE WI 54115

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: DTR CONCRETE PRODUCTS, LLC
Product Name: SEPTIC
Model Number(s): 1000
(41.0" L.L., 25 GAL/IN., 60" MAX. DEPTH OF BURY, 469 G.P.D. WHEN USED AS A SEPTIC
TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER)
Product File No: 20080507

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code.
This approval is valid until the end of JANUARY 2014.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This product is approved to use the following:
 - Department approved plastic risers and covers installed as required by product approval for the plastic risers and covers with the first riser cast into cover at time of tank production.
 - Conduit hole cast in riser for electrical wiring.
 - Polylok IV High Pressure Pipe Boot Seal by Polylok.
 - Four inch cast iron or schedule 40 ABS or PVC elbow cast in end of cover to create an inlet through the cover when the tank is used as a holding tank.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.

This approval supersedes the approval issued on 4/25/2007 under product file number 20070136. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20070136. **As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.**

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST; Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@wisconsin.gov